

Vegetation Management - Survey Report Form

nationalgrid

Job Reference Number: PG20241119164436
 Contractor: Ground Control Ltd
 Surveyors Name: Rod Taylor
 Contact Details: 0
 Additional Sheet Ref: N/A

Name: D MANDERFIELD
 Address: Caythorpe and Frieston PC. 17-19
 High Street, Caythorpe, Grantham,
 Lincs
 NG32 3DR

Site Address
 (if different) TRIANGULAR LAND
 END OF HOUGH ROAD
 JUNCTION WITH
 LINCOLN ROAD
 FRIESTON

Signed:

Telephone: 01400272561

Date:

Type: Land Owner

Emergency Access: TRIANGULAR LAND
 END OF HOUGH ROAD
 JUNCTION WITH
 LINCOLN ROAD
 FRIESTON

Nearest Telephone Point: MOBILE

Six Figure Grid Reference: SK941477

Nearest A & E: Grantham And District, 101 Manthorpe Rd,
 Grantham NG31 8DG TEL. 01476 565232.

I agree to the work(s) detailed below and on any additional referenced sheets to be carried out on behalf of National Grid Energy Distribution. This work is intended to achieve a compliant safety clearance for a period of five years. Where this ongoing clearance cannot be achieved through a single visit, I agree for the work(s) to be repeated at any time during the five year period commencing from the initial cut. I understand that I will always be contacted prior to any secondary work taking place and that this work (throughout the five year period) will be at no cost to me.

Tree ID reference	G55/3 Cat	Poles to/from or Site no.	Tree species	Work agreed	Achievable clearance (m) from conductors	ESQCR cat
T138008	A	2207040010S2	Atlas Cedar	Side Prune - unable to gain ENAT mature tree possible TPO needs engineer solution	1.50	N/A

WORK PICTURES

Number: 2207040010S2

Tree Reference: T138008

Work Reference: J981582



on:

